

Base register – 30000

Data Format – Big Endian

Register	Description
13098	mBC1 Status Bit 0 – Bus data shorted low, if set Bit 1 – Bus data shorted high, if set Bit 2 – No sensor present, if set Bit 3 – Power shorted to common, if set Bit 8 – Sensor bus fault, if set
13099	mBC2 Status
13100	mBC3 Status
13101	mBC4 Status
13104	Sensor #1 value (mBC #1 1 st sensor)
13105	Sensor #1 status Bit 0 – HA, if set Bit 1 – HW, if set Bit 2 – LW, if set Bit 3 – LA, if set Bit 8 – HA, if set Bit 9 – HW, if set Bit 10 – LW, if set Bit 11 – LA, if set
...	...
13168	Sensor #33 value (mBC #2 1 st sensor)
13169	Sensor #33 status
...	...
13232	Sensor #65 value (mBC #3 1 st sensor)
13233	Sensor #65 status
...	...
13296	Sensor #97 value (mBC #4 1 st sensor)
13297	Sensor #97 status